

---

**From:** 01 December 2023 15:56  
**Sent:** consult.2687  
**To:** FEBEG comments to the consultation on Elia's request for derogation on minimal  
**Subject:** exchange zone capacity to 70%

Dear Nico,

Please find hereafter our reaction to the public consultation.

FEBEG thanks CREG for having the opportunity to answer CREG's Public consultation on the derogation from the minimum available exchange capacity between zones.

We refer to our previous consultation on the matter.

In addition, Febeg appreciates the commitment of Elia to first use the PSTs to reduce loop flows before applying reductions of the RAM below 70%, and encourages CREG to assess the impact of this new approach before the next derogation request of 2025. This being said, the widespread use of PSTs cannot be seen as an "optimal" solution to address the concern of not reaching the minRAM 70% objective.

These comments are not confidential.

Do not hesitate to contact me if you have questions and/or remarks.

Best regards,

Regulatory manager wholesale markets electricity



Federation of Belgian Electricity and Gas Companies vzw/asbl  
Koningsstraat – Rue Royale 146  
1000 Brussels  
[www.febeg.be](http://www.febeg.be)

Please ~~consider the impact on the environment~~ before printing this e-mail